

Life Safety Self Inspection Report (If unchanged, please check Yes box. If changed, see page 3.)

ITEM	REQUIREMENT	COMPLIANCE?	
Egress-Secondary means of escape	Secondary means of escape shall be a door, stairway, passage, or hall providing a way of unobstructed travel to the outside of the dwelling at street or the finished ground level that is independent of and remote from the primary means of escape. OR it shall be an outside window operable from the inside without the use of tools, key, or special effort and have a clear width of no less than 20", clear height of no less than 24", opening of no less than 5.7 square feet and shall be no more than 44" above the floor. Windows shall be operable, meet minimum size requirements and not have bars or other obstructions that prevent egress. PROVIDE PHOTOGRAPHS OF ALL DOORS/WINDOWS THAT ARE SECONDARY MEANS OF EGRESS	YES	NO
Evacuation Diagram	Fire Safety and Evacuation Diagram shall be posted on interior bedroom walls adjacent to door. Diagram shall detail primary and secondary egress, location of fire extinguishers, and other life safety instructions. PROVIDE PHOTOCOPY OF THIS DIAGRAM	YES	NO
Outside Fires	All outdoor campfires require a firepit approved by the Fire Chief and a "Permit to Kindle Fire Authorization for Non-Property Owner." Every rental transaction is required to obtain a permit.	YES	NO
Signage.	Street Address shall be posted near driveway entrance in numbers not less than 3" tall with a minimum width of 1/2" on a contrasting background and visible from the street fronting the property.	YES	NO
Emergency Contact	Signage posted that contains the emergency contact information for guests, maximum number of guests, and copy of STR Permit.	YES	NO
STR Orientation Information for Guests	An informational brochure or binder that contains the following: - Trash disposal plan - Town noise ordinance - Local hospital addresses and contact numbers - Public nuisance information - Town's non-emergency police phone number - Maximum occupancy of the STR - Maximum number of vehicles that can be parked along with sketch that states, "No on-street parking is permitted." - Property owner signed copies of "Permit to Kindle Fire Authorization for Non-Property Owner," for each renter to apply for a permit. - Gas, water, and electrical shut-off and home heating appliance and safety manuals	YES	NO

PK

PK

NO OUTDOOR
FIREPITS ALLOWED

PK

PK

PK

*By signing below, I affirm and certify, under penalty of perjury, that the information contained herein is true and correct to the best of my knowledge and belief. **For renewals**, I affirm that no changes have been made to the rental property that would cause the affirmations and photographs previously submitted to no longer be valid. I agree to hold the Town of Freedom harmless for any damages resulting from applicant's misrepresentation, intentional or otherwise.*

I also certify under penalty of perjury, that I have read and understood the Town of Freedom Zoning Ordinance as it applies to the use of my property as a STR and that it doesn't relieve me from having to comply with any Local Ordinances, State or Federal Laws.

Signature of Property Owner: Paul W. Kiah Trowler Date Signed: 8/21/23
 Printed Name of Property Owner: PAUL W. KIAH